



- NOTES:
1. 1 1/2 INLET AND DISCHARGE DUCT FLANGES
  2. SERVICE ACCESS PANELS MUST NOT BE OBSTRUCTED RECOMMENDED CLEARANCE 24 INCHES.
  3. DIMENSIONS ARE SUBJECT TO MANUFACTURING TOLERANCES. FOR REFERENCE USE ONLY, SUBJECT TO CHANGE WITHOUT NOTICE.

**ICG**  
**WESTERN**  
**SALES**

TITLE  
15,000CFM CONVERTIBLE WET AIR HANDLING UNIT  
w/ HEAT WHEEL, HEATING/COOLING WATER COILS  
22" BI DWDI FAN c/w 20HP MOTOR (SUPPLY & EXHAUST)  
MODEL: AH-150-EW

DRAWN BY

ISSUED BY

SCALE

1/5"=1'

DRW. NO.

CHK. BY

DATE

JOB NO.

PAGE

Rev By

Revision Description

Date

E-13