


- NOTES:
1. 1 1/2 INLET AND DISCHARGE DUCT FLANGES
 2. SERVICE ACCESS PANELS MUST NOT BE OBSTRUCTED RECOMMENDED CLEARANCE 24 INCHES.
 3. DIMENSIONS ARE SUBJECT TO MANUFACTURING TOLERANCES.
- FOR REFERENCE USE ONLY, SUBJECT TO CHANGE WITHOUT NOTICE.

Rev	By	Revision Description	Date	 WESTERN SALES
				TITLE 2,000CFM ROOFTOP AIR HANDLING UNIT w/HEAT WHEEL, HEATING WATER COIL & PACKAGED COOLING 12" BI DWDI FAN c/w 2HP MOTOR (SUPPLY & EXHAUST) MODEL: AH-20-EW-DX05
DRAWN BY	ISSUED BY	SCALE 1/4"=1'	DRW. NO.	
CHK. BY	DATE	JOB NO.	PAGE E-23	