



NOTES:

⑤ SPLIT FOR SHIPMENT  
SEE CURB DWG. #60-18207

1. 1 1/2 INLET AND DISCHARGE FLANGES
2. SERVICE ACCESS PANELS MUST NOT BE OBSTRUCTED RECOMMENDED CLEARANCE 24 INCHES.
3. DIMENSIONS ARE SUBJECT TO MANUFACTURING TOLERANCES.  
FOR REFERENCE USE ONLY, SUBJECT TO CHANGE WITHOUT NOTICE

**ICE**  
**WESTERN**  
OSD SERIES

TITLE  
OSD 109  
165BI SWSI HRU HORIZONTAL CONFIG. OUTDOOR UNIT  
c/w MIX BOX, ANGULAR FILTER, HEAT WHEEL  
PLUG FAN AND LOUVERED INLET

DRAWN BY JV	ISSUED BY	SCALE 1:50	DRW. NO. 60-18206
CHK. BY	DATE	JOB NO.	PAGE H-20

Rev	By	Revision Description	Date
-----	----	----------------------	------