



NOTES:
 SEE ROOF CURB DWG. # 60-1
 (S) SPLIT FOR SHIPMENT
 1. 1 1/2 INLET AND DISCHARGE FLANGES
 2. SERVICE ACCESS PANELS MUST NOT BE OBSTRUCTED RECOMMENDED CLEARANCE 24 INCHES.
 3. DIMENSIONS ARE SUBJECT TO MANUFACTURING TOLERANCES.
 FOR REFERENCE USE ONLY, SUBJECT TO CHANGE WITHOUT NOTICE

ICE
WESTERN
 GIDM SERIES

TITLE
 GIDM 85-100 HORIZONTAL CONFIGURATION

DRAWN BY GDD	ISSUED BY	SCALE 1:28	DRW. NO. 60-01750B
CHK. BY	DATE	JOB NO.	PAGE J-22

Rev	By	Revision Description	Date
-----	----	----------------------	------