


NOTE:
SEE ROOF CURB DWG. #60-27448 RC.
1. 1 1/2 INLET AND DISCHARGE FLANGES.
2. SERVICE ACCESS PANELS MUST NOT BE OBSTRUCTED.
RECOMMENDED CLEARANCE 24 INCHES
DIMENSIONS ARE SUBJECT TO MANUFACTURING TOLERANCES.

			<div><div></div><div>WESTERN</div></div>				
Rev	By	Revision Description	Date				
				TITLE HTDM 1000 DX 50 MZ HORIZ. CONFIG. GRAVITY VENTED (18000CFM) OUTDOOR UNIT c/w FLT FILTER, MIX BOX w/ RETURN PACKAGED COOLING, AND LOUVERED INLET			
DRAWN BY JR		ISSUED BY SCALE 1:55		DRW. NO.			
CHK. BY		DATE		JOB NO.		PAGE J-13	