



- NOTE:
1. 1 1/2" INLET AND DISCHARGE FLANGES.
 2. SERVICE ACCESS PANELS MUST NOT BE OBSTRUCTED
 3. RECOMMENDED CLEARANCE 24 INCHES.
 3. DIMENSIONS ARE SUBJECT TO MANUFACTURING TOLERANCES.

AIRFLOW ARROWS

			<div>WESTERN SALES</div>					
Rev	By	Revision Description	Date					
<div><div>TITLE</div><div>HTDM 1000 GLYCOL RUNAROUND SYSTEM RTU-1,RTU-2,RTU-3,RTU-4</div></div>								
DRAWN BY		ISSUED BY		SCALE		DRW. NO.		
GDD				1:42		P00122		
CHECKED BY		DATE		JOB NO.		---		PAGE
								M-8